ORDINANCE NO. 10

Series, 1964

AN ORDINANCE AMENDING ORDINANCE NO. 3, SERIES, 1964, OF THE CITY OF ELGIN, OREGON, WHICH SAID ORDINANCE IS COMMONLY KNOWN AS THE "GAS ORDINANCE" AS TO SECTION 21, (1), AND AS TO SECTION 25 (4), AND DECLARING AN EMERGENCY.

THE CITY OF ELGIN ORDAINS AS FOLLOWS:

Section 1:

Ordinance No. 3, Series, 1964, of the City of Elgin, Oregon, as to Section 21 (1), be and the same is hereby amended to read as follows:

"(1) All gas service piping from the point of delivery to the first outlet, where the distance between these two points is fifty feet or less, and which said pipe carries a maximum of 250,000 BTU's per hour shall be not less than one (1) inch in diameter. All BTU loads in excess of 250,000 per hour shall be governed by the specifications set forth in the national bureau of fire underwriters handbook No. 54."

Section 2:

Ordinance No. 3, Series, 1964, of the City of Elgin, Oregon, as to Section 25 (4), be and the same is hereby amended to read as follows:

"(4) Tubing used to connect appliances where couplers are required shall be either two-foot copper couplers and/or three-foot flexible AGA approved couplers.

Section 3:

Whereas the peace, health and safety of the City of Elgin is involved and in order to properly safeguard the same, there is and now exists the necessity and emergency of immediate regulation of gas appliance installation, as hereinabove provided; now, therefore, an emergency is hereby declared to exist and this Ordinance shall be in full force and effect from and after its passage thereof and the approval by the Mayor.

PASSED by the City Council this 15 day of Sept, 1964.

APPROVED by the Mayor this 15 day of Sept, 1964.

Hayes C Parker
Mayor

ATTESTED and filed this 16 day of September, 1964.

Edith Ward
City Recorder